

**PROGRAMMATION USINE CYBLE RF MONTES SUR COMPTEURS
USINE HAGUENAU**

Compteurs	Seuil de fuite	Plage de réveil
Aquadis 25	35 l/h	6h-18h
Aquadis 30	50 l/h	6h-18h
Aquadis 40	100 l/h	6h-18h
Aquadis 65	120 l/h	6h-18h
Flodis 25	35 l/h	6h-18h
Flodis 32	60 l/h	6h-18h
Flostar M 40	90 l/h	6h-18h
Flostar M 50	90 l/h	6h-18h
Flostar M 65	120 l/h	6h-18h
Flostar M 80	180 l/h	6h-18h
Flostar M 100	300 l/h	6h-18h
Flostar M 150	600 l/h	6h-18h
Woltex M 50	450 l/h	6h-18h
Woltex M 65	750 l/h	6h-18h
Woltex M 80	1200 l/h	6h-18h
Woltex M 100	1800 l/h	6h-18h
Woltex M 150	4500 l/h	6h-18h
Woltex M 200	7500 l/h	6h-18h
Woltex M 250	12000 l/h	6h-18h
Woltex M 300	18000 l/h	6h-18h
Woltex M 400	30000 l/h	6h-18h

